

KALIKAPUR 1NO. GRAM PANCHAYET

VILL. + P.O. - Kalikapur, P.S. - Sonarpur, Dist. - South 24 Parganas

Prodhan
Madhab Chandra Mondal
Mob. : 98308 76264

Upa - Prodhan
Rumpa Naskar
Mob. : 90511 67291



Ref. No.

Date 30.05.2023

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Prodhan from KALIKAPUR 1NO. GRAM PANCHAYET inspected the Jyotirmoy Public School, Jyotirmoy Knowledge Park, Tematha, Kalikapur, Sonarpur, South 24 Parganas, West Bengal, Pin - 743330 on 22/05/23 and found that the Jyotirmoy Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school buildings & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of Five Years.

Musa

Prodhan 30.05.2023

Signature with Seal Kalikapur No.-1 Gram Panchayat
Sonarpur, South 24 Pgs

Name Madhab Chandra Mondal

Designation : Prodhan

Name & Address of the Office / Department :

To
The Principal
Jyotirmoy Public School
Jyotirmoy Knowledge Park,
Tematha, Kalikapur,
Sonarpur, Pin - 743330

Sushant Das

SUSHANT DAS
PRINCIPAL
JYOTIRMOY PUBLIC SCHOOL
SCHOOL CODE- 15644
TEMATHA, KALIKAPUR, SONARPUR
24 PGS. (S), W.B. - 743330

Rumpa Naskar
Manager

JYOTIRMOY PUBLIC SCHOOL
CBSE Affiliated Sr. Secondary School
Tematha, Kalikapur, Sonarpur
24 Pgs. (S), W.B. - 743330



Sl.No..... 21/135

Ramakrishna Mission Lokasiksha Parishad
Ramakrishna Mission Ashrama
Narendrapur, Kolkata – 700 103

**Water Quality Testing under NRDWQMS Programme in collaboration with
PHED, Govt. Of West Bengal**

TEST RESULT OF WATER SAMPLE

N.B.: Water samples and data supplied by a representative of the school.

		Date:22.09.23
Name of Owner	:	Jyotirmoy Public School
Type of Source	:	Filter Water
Location of Water-Source	:	At coridor
Address	:	Tematha, Kalikapur, Sonarpur, Pin-743330.

Date of Sample Collection	: 18.09.23
---------------------------	---	----------------


Parameters Test Report:

Name of Parameters	Date of Testing	Test Result	Permissible Limit (As per BIS)
pH	18.09.23 22.09.23	7.89	(6.5 – 8.5)
Turbidity		1.12 NTU	5 NTU
Hardness		336 mg/L	600 mg/L
Total Dissolved Solid (TDS)		843 mg/L	2000 mg/L
Iron		0.19 mg/L	1.0 mg/L

Bacteriological test Report:

Total coliforms CFU/100ml	Thermo tolerant coliforms CFU/100ml	Date of Testing	Test Result
0	0	18.09.23	contamination not found

Note: pH, Turbidity, Hardness, TDS and Iron values of the water sample are within the permissible limit of BIS. Bacteriological contamination not found.


.....
22/9/23
Signature of Co-ordinator

SUSHANT DAS
PRINCIPAL
JYOTIRMOY PUBLIC SCHOOL
SCHOOL CODE- 15644
TEMATHA, KALIKAPUR, SONARPUR
24 PGS. (S), W.B.-743330

Ripam Biswas
22/09/23
.....
Signature of Chemist

A. D. Chowdhury
22.09.23
.....
Signature of Bacteriologist


Manager
JYOTIRMOY PUBLIC SCHOOL
CBSE Affiliated Secondary School
Tematha, Kalikapur, Sonarpur
24 Pgs. (S), W.B. – 743330



Sl.No..... 21/023

Ramakrishna Mission Lokasiksha Parishad
Ramakrishna Mission Ashrama
Narendrapur, Kolkata – 700 103

**Water Quality Testing under NRDWQMS Programme in collaboration with
PHED, Govt. Of West Bengal**

TEST RESULT OF WATER SAMPLE

N.B.: Water samples and data supplied by a representative of the school.

		Date:15.05.23
Name of Owner	: Jyotirmoy Education and Welfare Foundation	
Type of Source	: Filter water	
Location of Water-Source	: Inside office building at ground floor	
Address	: Tematha, Kalikapur, Sonarpur, Dist.- South 24 Pgs	

Date of Sample Collection	: 12.05.23
---------------------------	---	----------------

Parameters Test Report:

Name of Parameters	Date of Testing	Test Result	Permissible Limit (As per BIS)
pH	12.05.23 15.05.23	7.27	(6.5 – 8.5)
Turbidity		0.96 NTU	5 NTU
Hardness		596 mg/L	600 mg/L
Arsenic		0.00 mg/L	0.01 mg/L
Iron		0.13 mg/L	1.0 mg/L
Manganese		0.03 mg/L	0.3 mg/L
Total Dissolved Solid (TDS)		1016 mg/L	2000 mg/L

Bacteriological test Report:

Total coliforms CFU/100ml	Thermo tolerant coliforms CFU/100ml	Date of Testing	Test Result
0	0	12.05.23	contamination not found

Note: pH, Turbidity, Hardness, Arsenic, Iron, Manganese and TDS values of the water sample are within the permissible limit of BIS. Bacteriological contamination not found.

Sushant Das
SUSHANT DAS
PRINCIPAL

JYOTIRMOY PUBLIC SCHOOL
SCHOOL CODE- 15644
TEMATHA, KALIKAPUR, SONARPUR
24 PGS. (S), W.B.-743330

Ripam Biswas
15.05.23

Signature of Chemist

Ripam Biswas
Manager
JYOTIRMOY PUBLIC SCHOOL
CBSE Aff. Secondary School
Tematha, Kalikapur, Sonarpur
24 Pgs. (S), W.B. – 743330

A.A. Chowdhury
15.05.23

Signature of Bacteriologist